

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1411:105 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Shoemaker Mfg. Company, 104 Montgomery Ave, Cle Elum, WA 98922
Contact: Jerry E. Hein (509) 674-4414 FAX (509) 674-4420

DESIGN: Models FD-111 and FSD-111 fire rated dampers. Units are multi-blade type of construction for vertical and/or horizontal installation.

SINGLE SECTION

Position	Min. Width	Max. Width	Min. Height	Max. Height
Vertical	8"	36"	8"	36"
Horizontal	8"	36"	8"	36"

MULTIPLE SECTION

Position	Max. Width	Max. Height
Vertical	72"	72"

RATING: 1-1/2 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as fire rated dampers for use with Models SQB-12.1, SQB-21.1, SQB-72.1, MA318, MA418, ML-4105, ML-8105, ML-4105, ML-8105, 3011, 331-4821, 331-2973, NF120 or NF24 damper operators.

NOTE: For listed leakage rating, refer to CSFM category 3230.

10-07-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**